

DOE/OE Transmission Reliability Program

Oscillation Monitoring System

Mani V. Venkatasubramanian

Washington State University, Pullman, WA

mani@eecs.wsu.edu

June 2014

Washington, DC



WSU Research Objectives

- **Oscillation Monitoring System for large power systems**
- **Monitoring **hundreds** of PMUs simultaneously**
- **System modes are changing – adaptive engines**
- **Interactions with power electronics**
- **Damping Monitor Engine – ambient data analysis**
- **Event Analysis Engine – detection and analysis of ringdowns and oscillations**
- **Real-time engines and off-line engines**



Key Accomplishments

- New algorithms developed for handling of large number of PMU measurements
 - Damping Monitor: DFDO, FFDD, RFDD, DFDD, RASSI, DRSSI
 - Event Analysis: MFRA, METRA
- FFDD implemented at Entergy; 5 Hz oscillations analyzed.
- Source of WECC 0.37 Hz low damping alarms identified to be forced oscillations from a hydro plant in Idaho







Complementary Engines

- Event Analysis Engine (EAE)
 - Multiple algorithms
 - Prony, Matrix Pencil, HTLS, ERA, MFRA, and METRA.
 - Aimed at events resulting in sudden changes in damping
- Damping Monitor Engine (DME)
 - Ambient noise based. Continuous. Provides early warning on poorly damped modes.
 - Several algorithms
 - Frequency Domain Decomposition (FDD), DFDO, Recursive Adaptive Stochastic Subspace Identification (RASSI), DFDD, RFDD, and DRSSI


Entergy 5.5 Hz oscillations



OMS FDD 5 Hz
mode energy level
captures the change.




Entergy 5 Hz oscillations




Mode
frequency
changes
during
some
days

Oscillations from different sources







5.45 Hz mode shape




5 Hz mode shape




0.38 Hz WECC mode (poorly damped)




June 13th PSD Singular Values from WECC data



Mode Shapes on June 13, 2013




**0.37 Hz at
Near Zero Damping Ratio
(7.30 am to 8.00 am)**



**0.4 Hz at
Near 8% Damping Ratio
(10 am to 11 am)**

June 13th 0.37 Hz oscillations at Generator



Generator MW Oscillations

- Hydro operated in rough zone when wind power output high.
- Vortex effect in Francis turbine when water flow level is low
- Air compressor to keep oscillations low to nil
- **5 to 25 MW oscillations observed at 0.37 Hz**
- Tricky for ambient mode monitoring engines
- Mode shape analysis critical
- Multi-dimensional analysis crucial

Forced Oscillations from Hydro

- Summer 2013 24 hour data: 0.37 Hz oscillations observed for several hours. Confirmed to be forced oscillations.
- Another 0.5 Hz oscillation also observed. Source points to hydro unit as well. Forced oscillations?
- Routine phenomenon in hydro units (Francis) when units come in and go out of system
- Detection? Impact on nearby system modes?
- Resonance possible when system mode poorly damped and close. Resonance observed in model simulations. Research and Algorithms at WSU.

Publications

- DFDO, IEEE Trans. Power Systems, May 2013
- RASSI, IEEE Trans. Power Systems, January 2014
- MFRA, IEEE Trans. Power Systems, March 2014
- METRA, Proc. HICSS, January 2014
- PMU applications, Springer-Verlag, M. Kezunovic, S. Meliopolous, V. Venkatasubramanian and V. Vittal, in print.

Technical Objectives in FY14

- **Damping Monitor Engine and Event Analysis Engine**
 - ◆ Design of **off-line** engine (Stage 3)
 - ◆ Code development, Testing, Training
 - ◆ Deliverables: Beta Engines and Training Modules for WECC and Entergy



Risk Factors in FY14

- **Event Analysis Engine and Damping Monitor Engine**
 - ❑ **PMU data quality**
 - ❑ **Computational complexity of algorithms**



Technical Objectives in FY15

- **Damping Monitor Engine and Event Analysis Engine**

- ◆ Real-Time Engine Prototype (Stage 3)

- ◆ Coding, testing, and tuning

- ◆ Deliverables: Beta versions for Entergy/WECC test labs and Training Modules

- ◆ Off-line Versions

- ◆ Continued Development, Testing and Training

